What's Wrong With My Water? Choosing the Right Test

Please let us know if this publication has helped you by taking a five-minute survey at www.ag.ndsu.nodak.edu/abeng/waterquality.htm.

Roxanne Johnson Water Quality Associate North Dakota State University

Tom Scherer, Ph.D. Extension Agricultural Engineer North Dakota State University

Who is Responsible?

Households using municipal or rural water supplies can depend on the utility to follow Environmental Protection Agency (EPA) guidelines for maximum levels of contaminants. An annual report is distributed to the users.

Private well owners are not monitored by government agencies. This means the owner must take responsibility for the condition of the system. Routine testing establishes a water-quality record. If a contaminant problem develops, correlating the cause is easier if you keep a water-quality record.



Fargo, North Dakota 58105

What's in Your Water?

Water is never just pure hydrogen and oxygen. Water naturally contains minerals and microorganisms from the rocks, soil and air in which it comes in contact. Human activities add many more substances to water. Some, such as bacteria, come from waste products of people and animals. Others, such as gasoline and industrial solvents, are synthetic chemicals, made and used for special purposes. Still other materials, such as nitrate and salt, occur naturally, but human activities can increase their concentrations in the environment. Which of the many potential drinking water contaminants should you be concerned about?

Reasons to Test Your Private Well

- Your well is new or recently serviced
- The area around the wellhead has been flooded or submerged
- Back-siphoning has occurred
- You have used, mixed or spilled pesticides near the well
- You have a heating oil tank or underground fuel tank near the well that has leaked

- You are pregnant, are planning a pregnancy or have an infant less than 6 months old
- Your or your neighbor's septic system absorption field is close to the well (within 100 feet)

Annual Baseline Testing

- Coliform (bacteria)
- Nitrate/Nitrite (forms of nitrogen)
- Total Dissolved Solids (salts)
- pH
- Any constituents that were at or near maximum safe drinking water limit standards in previous tests

Every Five Years

- The above tests
- A complete water chemistry analysis

Keep copies of ALL results so you can track changes in your water quality through time.

What to Test For

Problem or Concern	Symptoms	Water Test to Consider
Appearance	Frothy, foamy	Detergents
Appearance	Black flakes	Manganese
Appearance	Brown, yellow or reddish	Iron
Odor or taste	Rotten egg	Hydrogen sulfide
Odor or taste	Metallic	pH, iron, zinc, copper, lead
Odor or taste	Salty	Total dissolved solids, chloride, sodium, sulfates
Odor or taste	Septic, musty or earthy	Coliform bacteria, iron
Odor or taste	Soapy	Surfactants, detergents
Odor or taste	Gasoline or oil	Hydrocarbon scan, volatile organic chemicals (VOCs)
Stains on fixtures or clothing	Red or brown	Iron
Stains on fixtures or clothing	Black	Manganese
Stains on fixtures or clothing	Green or blue	Copper
Stains on fixtures or clothing	Reddish-brown slime	Iron bacteria
Stains on fixtures or clothing	White deposits, soap scum	Hardness (calcium and magnesium)
Discoloration of children's teeth		Fluoride
Gastrointestinal illness		Coliform bacteria, sulfates, Guardia
Pitting of plumbing fixtures and deposits on sinks and plumbing pipes	Corrosion	Corrosivity, pH, lead, zinc, manganese, copper, iron, sulfates, chloride
Leaking fuel tank		Hydrocarbon scan, VOCs
Road salt		Total dissolved solids, pH, VOCs, heavy metals
Sludge utilization		Coliform bacteria, nitrate, metals (lead, cadmium)
Septic system failure		Coliform bacteria, nitrate, detergents, total dissolved solids, chloride, sodium, sulfates
Intensive agricultural use		Coliform bacteria, nitrate, pesticide scan, pH, total dissolved solids

sion 1s

How Do I Test My Water?

Contact a certified lab for questions concerning sampling. A list of certified labs is available at http://www.ag.ndsu.nodak.edu/abeng/ waterquality.htm

Bacterial analysis

Most labs will provide a sterile collection container. This container may contain a chlorine inhibitor, so do not rinse the container prior to use.

Remove the aerator from the faucet if it has one. Sterilize the end of the faucet with a flame. Remove the bottle cap, taking care not to touch the inside of the cap or container.

To remove stagnant water from the system, run the water for 30 seconds and then fill the bottle to the line indicated or near the top. Immediately replace the bottle cap and secure transportation as soon as possible because coliform samples should be analyzed within 48 hours of collection.

Chemical analysis Well water

Pump the well for several minutes so the actual sample collected is from the groundwater source.

Tap water

Run the tap fully open for 30 seconds before collecting the sample.

Rinse the container two to three times with the water being collected unless preservative has been added to the container to maintain sample integrity (iron and manganese). Lead testing requires the water sample to be taken after the water has been sitting undisturbed in pipes. Do not run water prior to sampling.

Completely fill the container, leaving a small space for expansion of the liquid. Immediately replace the bottle cap.

Send the samples to the lab within 48 hours.

Common well head for a 4-inch diameter casing with submersible pump.



Good-quality (potable) drinking water is free from disease-causing organisms, harmful chemical substances and radioactive matter.

It tastes good, is aesthetically appealing and is free from objectionable color or odor.

Selecting the appropriate water treatment system

- **Point-of-entry** Treats water as it enters the residence.
- **Point-of-use** Treats water at a single tap. All filtration units can be fitted for whole-house application; however, expense may be a factor to consider.

Issue Treatment and Comments		
Tannins	Tea coloring formed during the decomposition of vegetation. pH more than 6.0 – anion exchange. pH less than 5.0 – activated carbon filter	
Staining	Water softener (cationic ion exchange) or iron/manganese filtration	
Odor: grassy or musty, chlorine, rotten egg, hydrogen sulfide – smell dissipates after 15 to 30 seconds, coliform bacteria – smell won't leave. <i>See instructions below.</i>	Activated carbon filtration Oxidizing filter Chlorination or aeration followed by filtration Manganese greensand, chlorination, aeration	
Odor: chemical	Stop chemical seepage, use activated carbon.	
рН	High or low pH can affect the efficiency of water treatment systems. Neutralizer filter	

Issue	Treatment and Comments	
Coliform	Shock chlorination with repeated testing should be done to determine if this is a one-time event from surface water contamination or if aquifers have been polluted. Ultraviolet disinfection may be used on a more permanent basis; however, sourcing the contamination needs to be a priority. Fecal coliform and E. coli, while not pathogens, are indicators of disease-causing microbes and water should not be used for drinking. Boiling water will kill coliform.	
Turbidity	No health effects. Can be addressed by removing the following: soil erosion, waste discharge, urban runoff; eroding stream banks; large numbers of bottom feeders (such as carp), which stir up bottom sediments; and excessive algal growth. Activated carbon filtration	
Chloride	Salty taste and with high levels, a laxative effect. Reverse osmosis, distillation	
Fluoride	Added to municipal water. Children under 9 should not drink water that has more than 2 mg/L of fluoride. Reverse osmosis, activated alumina or distillation	
Nitrate, Nitrites, Nitrate (as N)	High nitrate may cause methemoglobinema (blue baby) in infants who drink water or formula made from water with high levels. Health concerns with long-term use for adults. Reverse osmosis, distillation	
Arsenic to change A3 to A5 form	Known carcinogenic and associated with many health risks. Treatment is dependent on level of contamination. Chlorinate to change form, remove with filtration systemDistillation, reverse osmosis (A3 removal), alumina, anion exchange	
Alkalinity	Generally associated with high pH values, hardness and excess dissolved solids. Reverse osmosis or tank media	
Copper	Gastrointestinal distress to liver or kidney damage, depending on exposure time. Corrosion control including the addition of Poly 4 in crystal form to coat the pipes within your home. Distillation, reverse osmosis	
Hardness	Water softener (cation exchange)	
Iron Ferrous (clear and colorless when drawn) Ferric (ferrous water when exposed to air converts to reddish brown)	Iron: Bad metallic taste. Rust stains in toilets, plumbing fixtures, tableware and laundry. Water softener or oxidizing filter system	
Iron bacteria (red, orange, yellow water)	Iron bacteria: Slime on well screens, pipes and plumbing fixtures. Smell of fuel oil, cucumber or sewage. Shock chlorination	
Manganese (black)	Manganese: reddish-brown water, staining of plumbing fixtures and laundry. Off-taste and odor. Reverse osmosis or chlorination followed by oxidizing filter	
Lead	The pipes in your home are the likely source of high lead levels. Use only thoroughly flushed water from the cold tap for consumption. Reverse osmosis, distillation	
Sodium	Use potassium pellets instead of sodium softener pellets. Restrict drinking water from this source. Reverse osmosis, distillation	
Sulfates	May have a laxative effect on people Unaccustomed to the water. Reverse osmosis , distillation, anion exchange	
Total Dissolved Salts (TDS)	Adverse taste. Deteriorates plumbing and appliances. Reverse osmosis, distillation	

This publication may be copied for noncommercial, educational purposes in its entirety with no changes. Requests to use any portion of the document (including text, graphics or photos) should be sent to permission@ndsuext.nodak.edu. Include exactly what is requested for use and how it will be used.

For more information on this and other topics, see: www.ag.ndsu.edu

County Commissions, North Dakota State University and U.S. Department of Agriculture cooperating. Duane Hauck, Director, Fargo, North Dakota. Distributed in furtherance of the Acts of Congress of May 8 and June 30, 1914. We offer our programs and facilities to all persons regardless of race, color, national origin, religion, gender, disability, age, veteran's status or sexual orientation; and are an equal opportunity institution. This publication will be made available in alternative formats for people with disabilities upon request, (701) 231-7881.